



**HOUSING &
DEVELOPMENT
BOARD**

Flat Owner Address [REDACTED]
Contractor Ho Ho Engineering And Renovation Works
Authorised Person Ong Pai Lin
Application Date 16 Apr 2025
Application Number B-WL-01639-2025
Application Status Completed

Section A: Flat Owner Information

Name [REDACTED]
Renovation Address [REDACTED]
Mobile No. [REDACTED]
Email hohoengineering1976@yahoo.com.sg
Branch Woodlands Branch
HDB Officer [REDACTED]
Contact Number [REDACTED]
Town Council Marsiling-yew Tee Town Council

Section B: Renovation Works

S/N	Item Name	Material	Location	Status
1	Replacement of main entrance door and/ or frame to half hour fire-rated solid door Conditions: a. Door openings into passageways (such as staircases, lift lobbies) that serve as a mean of escape in case of fire, the new door/frame must be half hour fire rated solid door/frame with door closer. b. The main door to be minimum half hour fire rated with accreditors' label with self-closing device. Installation of localized home smoke/ fire alarm system within the unit is required by SCDF FSSD. c. Door and gate size, number of panels and direction of swing to be the same as HDB's original design. d. With effect from 1 Jun 2018, Installation of localised Home Fire/smoke Alarm Device (HFADs) within the unit is required by SCDF FSSD. e. For more info, including types, location and where to buy HFADs, pls visit SCDF website(www.scdf.gov.sg/HFAD).	-	-	Approved